

Trenton Public Schools
Lead in Water
Summary of Analytical Results and Recommended Remedial Responses

School	Sample Location	First Draw Results	Second Draw Results	Remedial Response
Columbus	Point of Entry outlet in Sprinkler Room	20.9		Investigate point of entry/service connection for lead components
Commissary	Mixing Kettle #2 in Kitchen	190	6.11	Replace Fixture and Supply Piping
Commissary	Water Fountain in Kitchen	40.3	N/A	Replace Fixture and Supply Piping
Daylight/Twilight	Point of Entry outlet in Sprinkler Room	77.7	130	Investigate point of entry/service connection for lead components
Grace Dunn	Slop Sink In Boiler Room	39.8	2.34	Install Sign "Handwashing Only, No Drinking or Cooking"
Grace Dunn	Water Fountain in Hallway by Room A-29X	612	N/A	Replace Fixture and Supply Piping
Grace Dunn	Water Fountain in Hallway By Room B-31	162	N/A	Replace Fixture and Supply Piping
Franklin	Water Fountain in Second Floor Hall	28	N/A	Replace Fixture and Supply Piping
Grant	Sink Faucet in Room A-25	35.3	<1.00	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Grant	Sink Faucet in Room A-26	46.6	3.03	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Grant	Sink Faucet in Room A-27	38.8	12.2	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Grant	Sink Faucet in Room AA-27	21.4	4.67	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Grant	Sink Fountain in Room AA-8	54.4	3.09	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Grant	Sink Faucet in Room AA-17	101	11.4	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Grant	Sink Faucet in Room BB-8	2,260	83.2	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Grant	Sink Faucet in Room BB-20	45.6	2.93	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Grant	Sink Fountain in Room BB-26	122	5.64	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Grant	Sink Faucet in Room B-16	44.6	28.8	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Grant	Sink Faucet in Room B-11	150	35.1	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Grant	Bubbler Water Fountain in Hall by Room B-10	60.3	N/A	Replace Fixture and Supply Piping
Gregory	Point of Entry outlet in Sprinkler Room	19.1	183	Investigate point of entry/service connection for lead components
Gregory	Sink Faucet in Room 102	24.9	2.8	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Gregory	Sink Faucet in Room 101	65.8	4.05	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Gregory	Sink Faucet in Room 201	67.2	9.13	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Gregory	Sink Faucet in Room 302	66.4	4.39	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Gregory	Sink Faucet in Room 308	57.1	35.3	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Harrison	Water Fountain in First Floor Hall	25.7	N/A	Replace Fixture and Supply Piping
Harrison	Water Fountain in Third Floor Hall	23	N/A	Replace Fixture and Supply Piping
Hedgepeth Williams	Sink Faucet in Room A-34	79.2	<1.00	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Hedgepeth Williams	Sink Faucet in Room A-32	43.7	3.69	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Hedgepeth Williams	Sink Faucet in Room A-24	35.6	1.43	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Hedgepeth Williams	Sink Faucet in Room A-30	15.1	4.69	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Hedgepeth Williams	Sink Faucet in Room A-26	40.1	3.01	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Hedgepeth Williams	Sink Faucet in Room A-27	513	38.1	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Hedgepeth Williams	Sink Faucet in Room A-29	288	478	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"

Trenton Public Schools
Lead in Water
Summary of Analytical Results and Recommended Remedial Responses

Jefferson	Sink adjcent to Point of Entry in Room 113	1,160	14.5	Install Sign "Handwashing Only, No Drinking or Cooking"
Jefferson	Bubbler Water Fountain in Gym adjcent to Boiler Room	196	N/A	Replace Fixture and Supply Piping
Jefferson	Sink Faucet in Room 201	27.1	16.5	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Jefferson	Water Fountain in Hall by Stairwell 1	18.1	N/A	Replace Fixture and Supply Piping
Jefferson	Water Fountain in Hall by Stairwell 2	21.6	N/A	Replace Fixture and Supply Piping
Jefferson	Water Fountain in Main Office	47.3	N/A	Replace Fixture and Supply Piping
Jefferson	Sink Faucet in Teachers Lounge	48	72.9	Replace Fixture and Supply Piping
Jefferson	Bubbler Water Fountain in Hall by Girls Restroom #71	24.8	N/A	Replace Fixture and Supply Piping
Jefferson	Bubbler Water Fountain in Hall by Boys Restroom #66	162	N/A	Replace Fixture and Supply Piping
ML King	Sink Faucet in Kitchen (Center Island)	44.9	<1.00	Replace Fixture and Supply Piping
Monument	Sink Faucet in Room AA-6	337	64.4	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Monument	Sink Faucet in Room A-5	64.7	2.08	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Monument	Sink Faucet in Room A-13	17.3	<1.00	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Monument	Sink Faucet in Room A-26	123	10.6	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Monument	Fountain at Sink Faucet in Room A-30	22.2	4.68	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Monument	Sink Faucet in Room B-1	21.6	1.9	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Monument	Sink Faucet in Room B-3	16.2	1.16	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Monument	Sink Faucet in Room B-15	17.4	1.91	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Monument	Sink Faucet in Room B-17	16.1	6.64	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Monument	Sink Faucet in Room B-8	53.9	4.45	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Monument	Sink Faucet in Room B-4	126	33.2	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Monument	Fountain at Sink Faucet in Room B-233	46.6	10.9	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Mott	Slop Sink In Boiler Room	145	7.76	Install Sign "Handwashing Only, No Drinking or Cooking"
Mott	Fountain at Sink in Room 103	67.2	28.1	Replace Fixture and Supply Piping
Mott	Fountain at Sink in Room 104	22.1	2.27	Replace Fixture and Supply Piping
Mott	Fountain at Sink in Room 201	29	9.19	Replace Fixture and Supply Piping
Mott	Fountain at Sink in Room 204	15.2	1.8	Replace Fixture and Supply Piping
Mott	Water Chiller Fountain Third Floor Hall	15.1	N/A	Replace Fixture and Supply Piping
Mott	Sink Faucet in Nurses Room	1,030	10.3	Replace Fixture and Supply Piping
Mott	Sink Faucet in Teachers Lounge	20.3	2.98	Replace Fixture and Supply Piping
Ninth Grade Academy	Point of Entry in Pump Room	28.5	39.2	Investigate point of entry/service connection for lead components
Parker	Slop Sink In Boiler Room	17.7	<1.00	Install Sign "Handwashing Only, No Drinking or Cooking"
Parker	Sink Fountain in Room 172	177	1.15	Replace Fixture and Supply Piping
Parker	Sink Fountain in Room 140	79.6	1.75	Replace Fixture and Supply Piping
Munoz Rivera	Slop Sink In Boiler Room	23.9	38.8	Install Sign "Handwashing Only, No Drinking or Cooking"
Munoz Rivera	Bubbler Water Fountain in Hall by Room B-19	314	N/A	Replace Fixture and Supply Piping
Munoz Rivera	Kettle Faucet in Kitchen at Freezer	1,400	288	Replace Fixture and Supply Piping
Munoz Rivera	Sink Fountain in Room 109	37.5	13.3	Replace Fixture and Supply Piping
Munoz Rivera	Sink Faucet in Room C-18	61.7	<1.00	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Munoz Rivera	Sink Faucet in Nurses Room	34.4	3.67	Replace Fixture and Supply Piping
Robbins	Water Fountain in Hall by Room 108	83.6	N/A	Replace Fixture and Supply Piping
Robbins	Water Fountain in Hall by Room 207	79.6	N/A	Replace Fixture and Supply Piping
Stokes	Point of Entry in Boiler Room	28.4	2.34	Investigate point of entry/service connection for lead components
Trenton Central West	Point of Entry in Boiler Room	172	18.9	Investigate point of entry/service connection for lead components
Trenton Central West	Ceramic Water Fountain in Room A-74	168	N/A	Replace Fixture and Supply Piping
Trenton Restorative	Sink Faucet in Teachers Lounge	20.1	13	Replace Fixture and Supply Piping

Trenton Public Schools
Lead in Water
Summary of Analytical Results and Recommended Remedial Responses

Washington	Point of Entry in Boiler Room	38	1	Investigate point of entry/service connection for lead components
Washington	Bubbler Water Fountain in in Hall by Room A-5	144	N/A	Replace Fixture and Supply Piping
Washington	Water Chiller Fountain in Hall Adjacent to Room A-6	126	N/A	Replace Fixture and Supply Piping
Washington	Sink Faucet in Teachers Lounge B-12	23	<1.00	Replace Fixture and Supply Piping
Washington	Water Chiller Fountain in Hall adjacent to Room B-6	25.1	N/A	Replace Fixture and Supply Piping
Wilson	Sink Faucet in Room A-11	21.2	17.2	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room A-12	55.3	5.5	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Teachers Lounge	17	8.31	Replace Fixture and Supply Piping
Wilson	Sink Faucet in Nurse Office	24.5	5.92	Replace Fixture and Supply Piping
Wilson	Sink Faucet in Room A-14	198	44	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room A-15	207	8.56	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room A-100	17.5	<1.00	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room C-2	224	51.1	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room C-3	64.8	1.81	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room C-4	1180	95	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room C-5	228	61.7	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room C-6	523	241	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room C-7	40.4	8.39	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room C-8	20.6	<1.00	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room C-9	23.6	3.97	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room C-10	51.6	<1.00	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room C-11	110	5.42	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room C-12	295	26.6	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room 200	250	1.62	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room B-12	63	1.58	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room B-1	601	94.1	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room B-2	482	55.4	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room B-11	29.3	1.45	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room B-10	351	4.92	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room B-4	91.8	1.43	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room B-9	64.2	2.86	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room B-5	32.6	<1.00	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room B-8	56.6	<1.00	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Wilson	Sink Faucet in Room B-7	26.3	<1.00	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Trenton Central HS	Point of Entry Outlet in Fire Pump Room	55.5	1.08	Investigate point of entry/service connection for lead components
PJ Hill	Sink in Room 105	15	1.42	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
PJ Hill	Sink in Room 106	82.2	2.84	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
PJ Hill	Sink in Room 219	29.2	4.07	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
PJ Hill	Sink in Room 202	51.2	6.23	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"

Trenton Public Schools
Lead in Water
Summary of Analytical Results and Recommended Remedial Responses

Joyce Kilmer	Point of Entry Outlet in Sprinkler Room	108	81.3	Investigate point of entry/service connection for lead components
Joyce Kilmer	Sink in Room 207	23.9	1.1	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"
Joyce Kilmer	Sink in Room 303	20.4	51.4	Replace Fixture and Supply Piping or Install Sign "Handwashing Only, No Drinking or Cooking"